

## Appendix GTC 3: Grid points and Gas Specification



Last update: 14/08/2013

Grid point ID	ETSO/EIC-Code	Grid point name	Flow direction	Grid point type	Adjacent system operator / storage operator	Gas specification
92200	21Z000000000241X	Greifswald OPAL	E	Interconnection point-international	---	1
92IEA	27ZG007P0000062W	Brandov	A	Interconnection point-international	---	2

**Explanation:**

A = Exit from network of OPAL Gastransport GmbH & Co. KG  
E = Entry into the network of OPAL Gastransport GmbH & Co. KG

		1	2
Contract location		Greifswald	Brandov
Gross Calorific Value (min)	kWh / m <sup>3</sup>	10,95	10,95
Gross Calorific Value (max)*	kWh / m <sup>3</sup>	11,70	11,70
Wobbe Index (min)*	kWh / m <sup>3</sup>	14,17	14,17
Wobbe Index (max)*	kWh / m <sup>3</sup>	15,25	15,25
Hydrocarbon dewpoint	°C / mg/m <sup>3</sup>	-2 °C @ 1 - 70 bar (a)	-2 °C @ 1 - 70 bar (a)
Water dewpoint	°C	-10 °C @ 70 bar (a)	-10 °C @ 70 bar (a)
Oxygen content (max)	ppm	100,00	200,00
Oxygen content (min)	mol-%	2,00	2,00
Hydrogen sulphide content H <sub>2</sub> S + COS (ma	mg /m <sup>3</sup>	5,00	5,00
Mercaptans (max)	mg /m <sup>3</sup>	6,00	6,00
Total sulphur (as S)	mg /m <sup>3</sup>	21,50	21,50
		**)	**)

\*) Gross Calorific Value and Wobbe Index are referring to a reference temperature of 298,15 K (25 °C) and combustion circumstances of 1,01325 bar and 273,15 K (0 °C).

\*\*) The Natural Gas delivered may not contain any other elements or impurities (such as, but not limited to methanol, condensates and gas odorants) to the extent that the Natural Gas delivered cannot be further transported, stored or marketed without incurring additional cost for quality adjustment.

This document is a convenience translation of the German original. In case of discrepancy between the English and the German versions, the German version shall prevail.